[See rule 7(3) (b) I]

CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT

Guaranteed Standards-Unplanned Power Supply Interruptions

Consumers Supply Voltage	Total Number of unplanned consumer Power Supply Interruptions	Number of Urban unplanned consumers Power Supply Interruptions (GSIU)		Number of Rural Unplanned consumers Powe Supply Interruptions (GSIR)	
		Restored within 10 Hrs:	Extending beyond 10 Hrs:	Restored within 16 Hrs:	Extending beyond 16 Hrs:
220 KV	-	-	-	-	-
132 KV (21 No GSS)	48	-	-	-	-
66 KV (01 No GSS)	6	-	-	-	-
33 KV	-	-	-	-	-
11 KV	2751	2751	-	-	-
400 / 230 V	110,844	73,687	-	37,157	-

Consumers Supply Voltage	Maximum permitted number of unplanned Power Supply Interruptions for each individual consumer per annum (GS2)	Number of consumers whose number of unplanned Power Supply Interruptions exceeded the maximum limit of GS2.	Maximum permitted aggregate duration of unplanned Power Supply Interruptions for each individual consumers per annum (hours) (GS3)	Number of consumers whose aggregate unplanned Power Supply Interruption time exceed the maximum limit of GS3.
220 KV	6	-	26	-
132 KV	6	-	26	-
66 KV	6	-	26	-
33 KV	30	-	44	-
11 KV	30	1	44	-
400 / 230 V Urban	60	183401	88	0
400 / 230 V Rural	80	602343	175 (distribution company), 240 for KESC	0

Form-2

[See rule 7(3) (b)]

CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT

Guaranteed Standards Planned Power Supply Interruptions

Consumers Supply Voltage	Maximum permitted number of planned Power Supply Interruption for each individual consumer per annum (GS4)	Number of consumers whose planned Power Supply Interruption exceeded the maximum limit of GS4	Maximum Power Supply Interruption aggregate duration (Hours) for each individual consumer per annum (GS5)	Number of consumers whose aggregate planned Power Supply Interruption duration exceeded the maximum limit of GS5
220 KV	4	-	36	-
132 KV	4	-	36	-
66 KV	4	-	36	-
33 KV	8	-	64	-
11 KV	8	0	64	0
400 / 230 V Urban	16	689093	80	689093
400 / 230 V Rural	16	565043	96	565043

Form-3

[See rule 7(3)-(b)

CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT

Guaranteed Standards-Unplanned Short Duration Power Supply Interruptions

Consumer Supply Voltage	Maximum permitted number of short duration Power Supply Interruptions for each individual consumer per annum (GS6)	Number of consumers whose short duration Power Supply Interruptions exceeded the maximum limit of GS6
132 / 66 KV	4	-
33 / 11 KV	140	-
400 / 230 V Urban	275	0
400 / 230 V Rural	300	0

Form -4

CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT

Overall Standards - Average Power Supply Interruption.

(With Load Shedding)

Consumer Supply Voltage	Total number of consumers served by the distribution company in a giver year	Total annual number of consumers Power Supply Interruptions	<u>SAIFI</u> (OS1) (4) = (3) / (2)	Aggregate sum of all consumers Power Supply Interruption Duration in Minutes	<u>SAIDI</u> (OS2) (6) = (5) / (2)
1	2	3	4	5	6
220 KV	-	-	-	-	-
132 KV	21	48	2.29	295	14.0
66 KV	1	6	6	36	36
33 KV	-	-	-	-	-
11 KV	318	3031	10	76550	241
400 / 230 V	2341901	117,864	0.05	3809161	1.63
TOTAL IESCO GENERAL CONSUMERS	2342219	120895	0.05	3885711	1.66

Form-5 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT

Guaranteed Standards – Time Frame for New Connections *

Eligible consumer's new Power Supply Connection requirements (Voltage and load level specific)	Maximum * time period of provision of new connection (calendar days) (OS3)	Total number of eligible consumers who applied for a new connection	Total number of eligible consumers who applied for a new connection and were connected within the maximum permitted time period of OS3	Total number of eligible consumer who applied for a new connection but did not receive connection thin the maximum permitted time period of OS3
Voltage level upto 400 V and load upto 15 KW (Urban)	30	33,802	33,802	0
Voltage level upto 400 V and load upto 15 KW (Rural)	30	36,331	36,331	0
Voltage level upto 400 V and load above 15 KW but not exceeding 70 KW	53	562	562	0
Voltage level upto 400 V and load above 15 KW but not exceeding 500 KW	73	150	150	0
Voltage level 11KV or 33KV and load above 500KW but not exceeding 5000 KW	106	5 (AJK New Bulk supply 11 KV Cons)	5 (AJK New Bulk supply 11 KV Cons)	0
Voltage level 66KV and above for all loads	496	0	0	0

Form-6

[See rule 7(3)(b)

CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT

Overall Standards-Nominal Voltages

Consumers Supply Voltage (OS4)	Maximum permitted voltage level deviations	Number of consumers who requested their Power Supply voltage levels to be checked	Number of times where a remedial action followed a consumer request above his Power Supply voltage level check
220 KV (if applicable)	+/- 5%	-	-
132 KV	+/- 5%	-	-
66 KV	+/- 5%	-	-
33 KV	+/- 5%	-	-
11 KV	+/- 5%	10	1-2 Time Each
400 / 230 V Urban	+/- 5%	3962	1-2 Time Each
400 / 230 V Rural	+/- 5%	2485	1-2 Time Each

Form-7

[See rule 7(3)(b)

CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT

Overall Standards-Frequency

Consumers frequency	Maximum permitted frequency deviations	Total number of consumers who requested their frequency levels to be checked	Total number of times where a remedial action followed a consumer request about his frequency level check
50 Hertz	+/- 1%	Nil	Nil

Form-8 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT

Overall Standards-Frequency

Priority group consumers	Number of instances of actuation of load shedding (OS6)	Average duration of load shedding period (Hours) per day	Maximum duration of load shedding period (Hours) in a day	Number of Consumers affected in each priority group	Load (MW) interrupted due to load shedding in each priority group
Consumer in Rural area and in Urban area	256396	4 – 6	8 – 10	1542875	380 - 490 (MW)
Consumer other than industrial in urban areas	97438	4 – 6	8 – 10	726,604	270 - 325 (MW)
Agricultural consumers where there is dedicated Supply	0	0	0	0	0
Industrial consumers	Mandatory load reduction / Load Management as per PEPCO instructions (4-6 Hrs)			6,648	300 - 350 (MW)
Supply to Schools and Hospital	14889	4 – 6	8 – 10	1592	35 - 50 (MW)
Defence / Strategic Installations	Exempted from load shedding				

Form-9 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT Overall Standards-Safety

Type of Incident	Number of Electrical incidents	Average duration of absence from work	Longest duration of absence from work
Electrical incident resulting in death or permanent serious injury / disability to member of staff	10 Nos. (Fatal Accidents)	-	-
Electrical incident resulting in injury to member of staff requiring hospital treatment or absence from work for five days or more.	16 Nos. (Non Fatal Accidents)	1-2 Months	02 Months
Electrical incident resulting in injury to member of staff requiring absence from work for 1-5 days.	-	-	-
Electrical incident resulting in injury to member of staff not requiring absence from work	-	-	-
Electrical incident resulting in death or permanent serious injury / disability to member of the public	2	-	-
Electrical incident injuring member of the public involving distribution company's plant or equipment	2 No Fatal Accidents & No Non Fatal Accidents	-	-
Electrical incident injuring member of the public not involving distribution company's plant or equipment	-	-	-
Safety reports received on toll free telephone number	-	-	-

Form-10 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT Consumer Formal Complaints Report

Nature of Complaints	Received by person	Received by Telephone	Received Electronically	Received in writing	Average time in hours to resolve a complaint	Longest time in hours to resolve a complaint
Price of Electricity	6847	3232	45	3442	2 Hour	4 Hour
Reliability of Supply	6575	6358	161	2143	2 Hour	4 Hour
Planed interruptions	7552	11900	18	1407	2 Hour	6 Hour
Supply Voltage level	5247	2173	90	2560	2 Hour	4 Hour
New Connection	2897	1318	136	1310	168 Hour (1 Week)	Subject to availibility of material
Safety	96	125	0	118	4 Hour	6 Hour
Other	478	397	0	114	2-4 Hour	8 Hour

Form-11

[See rule 7(3)(b)

CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT System Performance

System Voltage	Total length of Distribution System in Service (Km)	Total number of Distribution System Faults	Faults / 100 Km of Distribution System
220 KV (if applicable)	-	-	-
132 KV	2717	88	3
66 KV	581	8	1
33 KV	153	29	19
11 KV	23603	57908	245
400 / 230 V	26012	188860	726